

Items Excluded from American Iron and Steel Compliance Provisions

Products not made primarily of iron or steel = < 50% of the material costs are tied up in iron and/or steel

Products not permanently incorporated into the project, removed following construction (i.e. scaffolding)

Reused item - provided that the item is not substantially altered from original form/function, and any restoration work does not include the replacement or addition of foreign iron or steel replacement parts

Excluded Items:

Aeration equipment

Analytical instrumentation

Blowers

Cabinetry

Clarifier mechanism

Clarifiers

Coatings to external surfaces

Compressors

Controls

Conveyors

Cranes

Dewatering equipment

Disinfection

Drives including VFDs

Electrical components, equipment and systems, typically powered by electricity and includes components that are part of the electrical distribution system

Electrical conduit

Emergency life systems

Filters

Gates - such as sluice or slide gates, does not include gate valves

Gear reducers

Generators

Grinders

Heat exchangers

Housings, such as electrical boxes/enclosures

HVAC, excluding ductwork

Laboratory equipment

Lighting fixtures

Mechanical components, equipment and systems, typically having motorized parts and/or is powered by a motor

Membrane bioreactor systems

Membrane filtration systems

Metal office furniture

Meters - flow meters, wholesale meters, water meters, service connections

Mixers

Motorized screens, such as traveling screens

Motors

Presses, including belt presses

Pumps

Pumping assembly

Rakes

Reverse osmosis package plant

SCADA

Sensors

Shelving

Switches

Valve actuators

Valve controls and operators, whether electric, pneumatic, or manual accessories to operate valves

Valve or hydrant nuts and bolts

Water heaters